

Bentazon		<0.010	µg/l	GC/MS/SIM AK. 78	0.1
Isoproturon		<0.010	µg/l	LC/MS/SIM AK. 78	0.1
Linuron		<0.010	µg/l	GC/MS/SIM AK. 78	0.1
Pendimethalin		<0.010	µg/l	GC/MS/SIM AK. 78	0.1
Diuron		<0.010	µg/l	LC/MS/SIM AK. 78	0.1
Metamitron		<0.010	µg/l	LC/MS/SIM AK. 78	0.1
Chloridazon		<0.010	µg/l	LC/MS/SIM AK. 78	0.1
Hexazinon		<0.010	µg/l	LC/MS/SIM AK. 78	0.1
Cyanazin		<0.010	µg/l	LC/MS/SIM AK. 78	0.1
Dimethoat		<0.010	µg/l	LC/MS/SIM AK. 78	0.1
Desethylterbutylazin		<0.010	µg/l	LC/MS/SIM AK. 78	0.1
4-chlor-2-methylphenol	#	<0.010	µg/l	GC/MS/SIM AK. 158	0.1
2,4-dichlorphenol	#	<0.010	µg/l	GC/MS/SIM AK. 158	0.1
Pentachlorphenol	#	<0.010	µg/l	GC/MS/SIM AK. 158	0.1

KOMMENTARER

Højest tilladelige værdi er overholdt for de undersøgte parametre.



Henrik Olsen